Job Name/Location:

Date:

PO No.:

Architect:

Engr:

Mech:

(Company)

(Project Manager)

Tag #:

Resubmit

Approval Other

Resubmit

Approval Other

(Project Manager)

## LS120HEV

Mega Single Zone Inverter

Outdoor Unit (ODU) - LSU120HEV Indoor Unit (IDU) - LSN120HEV

#### **Performance:**

### Cooling:

Capacity (Btu/h)	12,000
SEER	16.3
EER	10.26

SEER - Seasonal Energy Efficiency Ratio EER - Energy Efficiency Ratio

Heating:

Capacity (Btu/h)	12,000
HSPF	8.5

HSPF - Heating Seasonal Performance Factor

Cooling Nominal Test Conditions: Heating Nominal Test Conditions: Indoor: 80°F DB/67°F WB Indoor: 70°F DB/60°F WB
Outdoor: 95°F DB/75°F WB Outdoor: 47°F DB/43°F WB

#### Electrical: Outdoor Unit:

Power Supply (V¹/Hz/Ø)	208-230/60/1
MOP (A)	15
MCA (A)	9
Cooling Rated Amps (A)	7.3
Heating Rated Amps (A)	7.3
Compressor (A)	6.8
Fan Motor (A)	0.5

MOP - Maximum Overcurrent Protection MCA - Minimum Circuit Ampacity

#### **Indoor Unit:**

Power Supply (V¹/Hz/Ø)	208-230/60/1
Cooling Power Input (kW)	1.17
Heating Power Input (kW)	0.98

### Piping:

Liquid Line (in, OD)	1/4
Vapor Line (in, OD)	3/8
Additional Refrigerant (oz/ft)	0.22
Max Pipe Length (ft) <sup>2</sup>	49
Piping Length (no add'l refrigerant, ft)	25
Max Elevation (ft)	23

## **Controls Features:**

•24-Hour on/off timer •Energy saving

•2-Way (up/down) auto •Inverter (variable speed

swing compressor)Auto changeoverJet cool

•Auto restart •Self-cleaning indoor coil

•Condensate sensor •Sleep mode

connection •Ultra quiet operation





## **Operating Range:**

#### **Outdoor Unit:**

Cooling (°F DB)	64-118
Heating (°F DB)	23-75
Indoor Units	

#### Indoor Unit:

Cooling (°F DB)	64-86
Heating (°F DB)	690-86

#### **Unit Data:**

Refrigerant Type	R410A
Refrigerant Control	Capillary Tube
Refrigerant Charge (lbs)	1.65
ODU Sound Pressure (±3 dB(A)) <sup>3</sup>	47
IDU Sound Pressure ±3 (H/M/L) dB(A) <sup>3</sup>	39/33/25
ODU Net Unit Weight (lbs)	49
ODU Shipping Weight (lbs)	53
IDU Net Unit Weight (lbs)	20
IDU Shipping Weight (lbs)	25
Heat Exchanger Coating	GoldFin™

#### Fan:

ODU Type		Propeller
IDU Type		Cross Flow
Fan Speeds (Fan/Coolin	ng/Heating)	3/4/3
Quantity (ODU + IDU)		1+1
Motor/Drive	Brushless Digi	tally Controlled/Direct
ODU Max Air Flow Rate	(CFM)	956
IDU Air Flow Rate H/M,	/L (CFM)	353/272/212
Dehumidification (pts/h	nr)	2.75

## Notes:

- 1.Acceptable operating voltage: 187V-253V.
- 2. Piping lengths are equivalent.
- 3.Sound Pressure levels are tested in an anechoic chamber under ISO Standard 1996.
- 4.All power/communication cable to be minimum 18 AWG, 4-conductor, stranded,
- shielded and must comply with applicable local and national code. 5.See Engineering Manual for sensible and latent capacities.
- 6. Power wiring cable size must comply with the applicable local and national code.
- 7.The indoor unit comes with a dry helium charge
- 8.This data is rated 0 ft above sea level, with 24.6 ft of refrigerant line and a 0 ft level difference between outdoor and indoor units.
- 9.Must follow installation instructions in the applicable LG installation manual.





# Outdoor Unit (ODU) - LSU120HEV


Mega Single Zone Inverter





Tag #:

Date:

PO No.:







ltem No.	Part Name	Remarks
1	Air Discharge Grille	
2	Gas Pipe Connection Port	
3	Liquid Pipe Connection Port	
4	Control Box	
5	Earth Screw	


## Indoor Unit (IDU) - LSN120HEV Mega Single Zone Inverter




Tag #:

Date:

PO No.:





Item No.	Part Name	Remarks
_	Front Panel	
2	Display & Signal Receiver	
ω	Air Suction Grille	
4	Knockout hole	For pipe and cable
5	Installation Plate	